

पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड

(भारत सरकार का उद्यम)



पावरग्रिड

**POWER GRID CORPORATION OF INDIA LIMITED**

(A Government of India Enterprise)

केन्द्रीय कार्यालय: "सौदामिनी" प्लॉट सं. 2, सेक्टर-29, गुरुगॉंव-122 001, हरियाणा  
फोन : 2571700 - 719, फैक्स : 2571760, 2571761 तार 'नेटग्रिड'  
Corporate Office : "Saudamini" Plot No. 2, Sector-29, Gurgaon-122 001, Haryana  
Tel. : 2571700 - 719, Fax : 2571760, 2571761 Gram : 'NATGRID'

REF: C/QA&I/SV/2488

Date: 15/10/2004

ABB Ltd.,  
Plot no. 5 & 6 , II Phase  
Peenya Industrial Area,  
P B no. 5806, Peenya,  
Banglore - 560058

Attn: Shri C G Jagadeesh ; Manager Head ( QA )

Sub: Approval of sub-vendor for Carrying Panel assembly and wiring for C&R Panels

Dear Sir,

This has reference to your letter no. nil dated 22/09/2004 regarding the above subject .


We have reviewed your request and based on the assessment carried out by our representative , hereby accept Ampere Electric Systems ( AES ) , no. 43, Byraveshwara Industrial Estate, Peenya IInd Stage, Banglore as sub-vendor for Carrying Panel assembly and wiring for C&R Panels in POWERGRID projects. However, you are requested to ensure the followings :

1. Materials required for assembly to be procured and inspected by ABB Ltd as per POWERGRID approved MQP before handing over to AES for assembly and wiring of panels
2. Job cards / route cards to be made available with each panel showing stages of inspection with signature
3. Mounting of relays , modules and relay accessories etc and its wiring to be done at ABB premises
4. All activities at sub-vendors' premises should be under supervision of ABB. Panel to be inspected and cleared by ABB before shifting from AES for assembly and wiring at ABB.
5. Final inspection and testing will be at ABB premises.

Please note that this approval does not absolve your any liability as per the terms of any contract.

Thanking you,

Yours truly,

  
( D. Chakraborty )  
Dy General Manager ( QA&I )